



Air Monitoring Data Report

The attached table summarises the results of emissions testing carried out on the Visy Gas Fired Boilers combined Discharge Stack for the 2018/19 Reporting Period.

Site: Visy Paper Pty Ltd, Smithfield NSW Licence No: 4100

Date of Test: 8 February 2021 Tester: Ektimo Pty Ltd

Report No: R010404 Report Date: 26 February 2021

Table 1: Summary of Average Emission Test Results (Report No. R009395)

Pollutant	Unit of measure	Concentration limit	Result	Compliance
Nitrogen dioxide	mg/m³	250*	7.9	Yes
Nitric oxide	mg/m³	250*	90	Yes
Oxygen	%	N/A	3.9	N/A
Temperature	°C	N/A	111	N/A
Velocity	m/s	N/A	7.7	N/A
Volumetric flow rate	m³/s	N/A	14	N/A
Dry gas density	kg/m³	N/A	1.33	N/A
Moisture	%	N/A	14	N/A
Molecular weight stack gases	g/gmol	N/A	29.8	N/A

All results comply with the Environmental Protection Licence emission limits.

Verified by: Date: 25/10/2021

Ben Casauria

Visy National Environment Manager